

LDW SF 12.3.54

04/28/06

R# 11872

5/1/06

Elizabeth Gilpin

From: Penswick, Steve @ DUW [spenswick@glaciernw.com]
Sent: Friday, April 28, 2006 2:40 PM
To: Elizabeth Gilpin
Subject: Dust Collector Logs
Attachments: NEW DUST COLLECTOR LOGS.xls

Glacier NW, W Marginal

Hello Elizabeth,

Attached are our new dust collector log sheets. Please review and if you have anything you would like to add, please let me know. I will send you our updated inspection forms early next week.

Thanks,

Steve Penswick
Glacier Northwest
Seattle Cement Terminal

5/1/2006

USEPA SF



1270008

GLACIER NORTHWEST
SEATTLE CEMENT TERMINAL
DUST COLLECTOR LOGS

WEEKLY INSPECTION
DUST COLLECTOR NUMBER 1

OPERATION RANGE FOR DP READINGS IS 2-5"

DATE	DP READING	VISIBLE EMISSIONS****	NO VISIBLE EMISSIONS	FALLOUT	NO FALLOUT

IF DP READING IS OVER 5" INSPECT CARTRIGES AND DESCRIBE CONDITON

****IF EMISSIONS ARE PRESENT:

- 1) STOP EQUIPEMENT IMMEDIATELY UNTIL EMISSIONS ARE CORRECTED
- 2) NOTIFY MANAGEMENT AND MAINTENANCE
- 3) LIST ACTIONS TAKEN TO CORRECT BELOW
- 4) ACTION MUST BE TAKEN WITH 24 HRS.

IF DP READING IS OVER 8" CHANGE CARTRIDGES

WEEKLY INSPECTION
DUST COLLECTOR NUMBER 2

OPERATION RANGE FOR DP READINGS IS 2-5"

DATE	DP READING	VISIBLE EMISSIONS***	NO VISIBLE EMISSIONS	FALLOUT	NO FALLOUT

IF DP READING IS OVER 5" INSPECT CARTRIGES AND DESCRIBE CONDITON

****IF EMISSIONS ARE PRESENT:

- 1) STOP EQUIPEMENT IMMEDIATELY UNTIL EMISSIONS ARE CORRECTED
- 2) NOTIFY MANAGEMENT AND MAINTENANCE
- 3) LIST ACTIONS TAKEN TO CORRECT BELOW
- 4) ACTION MUST BE TAKEN WITH 24 HRS

IF DP READING IS OVER 8" CHANGE CARTRIDGES
